



Guru Nanak Public School

Principal

Guru Nanak Public School

Secretary

Government Of West Bengal
Office Of The Director General
West Bengal Fire & Emergency Services
13D, Mirza Ghalib Street, Kolkata - 16

Memo no.:IND/WB/FES/20192020/68909

Date: 01-08-2023

From:
Divisional Fire Officer
Fire Prevention Wing,
West Bengal Fire & Emergency Services

To: GURU NANAK PUBLIC SCHOOL
NEW KOLORAH, ANDUL ROAD, ALAMPUR, P.S. SANKRAIL HOWRAH

Sub: Renewal of Fire Safety Certificate for the occupancy of G+4 storied educational building in the name and style of Guru Nanak Public School, New Kolorah, Andul Road, Alampur, P.S.- Sankrail, Howrah- 711302.

This is in reference to your application no. 0125191231300207 dated 23-06-2023 regarding the Renewal of Fire Safety Certificate for the occupancy of G+4 storied educational building in the name and style of Guru Nanak Public School, New Kolorah, Andul Road, Alampur, P.S.- Sankrail, Howrah- 711302.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Driveway.
2. The interior finish decoration of building shall be made with low flame spread material confirming I.S. specification.
3. To eliminate risk of Fire Hazard good house-keeping both for inside and outside of the building shall be strictly maintained.
4. Existing electrical wiring of the whole building shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling and duct.
5. The notice of Fire Fighting and Evacuation from the building shall be prepared and displayed at all vulnerable places of the building.
6. The employees and security staffs shall be conversant with installed Fire Fighting Equipments of the building and to

ate in the event of Fire & Testing.

Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants, employees, security personnel of the building.

8. First Aid Fire Fighting system shall be provided as per I.S. specification.

9. Arrangement shall have to be made for regular checking, testing and maintenance of all the Fire Fighting installations and equipments in the building to keep them in perfectly good working condition at all the times.

10. Periodical flashing of water from the hydrant and hose reel hose shall be made to maintain the efficient working performance of above mentioned system.

11. The Fire Safety audit to be conducted a regular interval and to be recorded in the Fire Prevention maintenance register.

12. No changes shall be done in the buildings that will affect the means of escape. Any deviation in the above and failure in maintenance of the Fire Prevention and Life Safety Measures shall be at the risk and liability of the owner.


13. Any deviation and failure in maintenance of the Fire Prevention and Fire Safety measures will be at the risk and liability of the Head of the Organization.

14. This renewal of Fire Safety Certificate is valid for three years and has to be renewed every interval of three years from the date of issue of this letter.


Validity unknown
Digitally Signed
Name: NIHAR RANJAN ROY
Date: 01-Aug-2023 11:31:23
Reason: Approved
Location: West Bengal

Divisional Fire Officer
West Bengal Fire & Emergency Services

Guru Nanak Public School


Secretary

Guru Nanak Public School


Principal 02/02/2026