

# Results of Bacteriological Examination


## DISTRICT LABORATORY UNDER HOWRAH DIVISION


### PUBLIC HEALTH ENGINEERING DIRECTORATE

DATE OF REPORT	23.09.2025
SAMPLE NO	6052
SAMPLE SOURCE	Drinking Water from Guru Nanak Public School, (Raw Water) New Kalora, Andul Road, Alampur, Howrah
SAMPLE COLLECTED BY	Gadadhar Dey (Teacher of this School)
DATE OF COLLECTION	22.09.2025
PERIOD OF TESTING	22.09.2025 -23.09.2025


SL. NO.	PARAMETERS	DESIRABLE LIMIT	URESULT
1	Total Coliforms (CFU/100ml)	Nil	Nil (Not detected)
2	Faecal Coliforms (CFU/100ml)	Nil	Nil (Not detected)

N.B : sample was not collected by the department, hence source and depth not confirmed.


  
Bacteriologist  
Howrah Dist. Lab  
PHE Dte.

  
Asst. Engineer  
Howrah Division  
PHE Dte.

Guru Nanak Public School

  
Secretary

Guru Nanak Public School

  
Principal 02/09/2026



# Results of Chemical Examination

DISTRICT LABORATORY UNDER HOWRAH DIVISION  
PUBLIC HEALTH ENGINEERING DIRECTORATE



DATE OF REPORT	23.09.2025
SAMPLE NO.	6053
SAMPLE SOURCE	Drinking Water from Guru Nanak Public School, (Filter Water) New Kalora, Andul Road, Alampur, Howrah
SAMPLE COLLECTED BY	Gadadhar Dey (Teacher of this School)
DATE OF COLLECTION	22.09.2025
DATE OF TESTING	22.09.2025

SL NO.	Parameters	Expressed As	Recommended Drinking Water Quality as per IS 10500: 2012 (Second Revision)		RESULT
			Acceptable Limit (Max)	Permissible Limit (Max)	
1.	pH	-	6.5 - 8.5	No relaxation	6.80
2.	Turbidity	NTU	1	5	0.01
3.	Total Dissolved Solid	mg/l	500	2000	30
4.	Total Hardness	mg/l	200	600	10
5.	Chloride	mg/l	250	1000	3.97
6.	Iron	mg/l	1.0	No relaxation	0.05
7.	Manganese	mg/l	0.1	0.3	BDL
8.	Arsenic	mg/l	0.01	No relaxation	BDL
9.	Salinity	ppt	-	-	0.0

N.B : Sample was not collected by the department, hence source and depth not confirmed.

Chemist  
Howrah Dist, Lab  
PHE Dte

Asst. Engineer  
Howrah Division  
PHE Dte.

Guru Nanak Public School

Secretary

Guru Nanak Public School

Principal  
02/02/2026

সমষ্টি স্বাস্থ্য অধিকারিকের করণ

সাঁকরাইল ব্লক

হাজি এস টি মল্লিক গ্রামীণ হাসপাতাল

থানা - সাঁকরাইল, জেলা-হাওড়া,

পিন - ৭১১৩১৩

ফোন নং - ০৩৩-২৬৭৯-৭৫০৩



OFFICE OF THE BLOCK MEDICAL OFFICER OF HEALTH

SANKRAIL BLOCK

HAZI S T MULLICK RURAL HOSPITAL

P.S-SANKRAIL, Dist- Howrah, Pin. - 711313

E-mail:- [sankrailbmoh1a@gmail.com](mailto:sankrailbmoh1a@gmail.com)

PHONE NO-033-2679-7503

MEMO NO-BMOH/SANK/ 1133

DATE- 20/09/25

**TO WHOM IT MAY CONCERN**

This is to certify that the **Guru Nanak Public School** of Mouza Garmizapur, P.O.-New Kolorah, Andul Road, Alampur, P.S.-Sankrail, Howrah-711302, situated near the N.H.-6, Alampur.

As per the verification on 19/09/2025, I certified that all the sanitary condition is well & good. The class rooms and floors are hygienic for health.

Thanking you.

Yours faithfully

BMOH

HAZI ST MULLICK RH

SANKRAIL HOWRAH

*Block Medical Officer of Health*

Sankrail Block

HAZI S. T. MULLICK R. H.

Sankrail, Howrah

Guru Nanak Public School

Secretary

Guru Nanak Public School

Principal 02/09/2026